

ボーリング柱状図

調 査 名 公立沖縄北部医療センター建設工事基本設計業務（付属棟研修医療敷地）

[illegible]

事業・工事名

シート No

標尺	標高	層厚	深度	柱状図	土質区分	色調	相對密度	相對稠度	記事	孔内水位(m)／測定月日	標準貫入試験					原位置試験		採取方法	室内試験(月日)	掘進(月日)					
											深	10cmごとの打撃回数			打撃回数／貫入量	N値	深				試験名および結果	深	試験番号		
												度	0	10										20	度
(m)	(m)	(m)	(m)								(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)	(m)			
1					シルト質砂	橙～淡橙褐			上部10cm草根。 以深、粗砂を主体に所々にシルト分を多く含む。 緯度経度は簡易GPSより測定		1.15	1	2	2	5/30	5									
2							1.45	2		3	3	8/30	8												
3							2.45	2		3	3	8/30	8												
4							3.15	2		3	3	8/30	8												
5							3.65	2		3	3	8/30	8												
6	11.90	6.00	6.00		シルト質砂	淡橙褐				4.15	2	3	3	8/30	8										
7							4.45	2	3	3	8/30	8													
8							5.15	2	3	3	8/30	8													
9							5.45	3	5	5	13/30	13													
10	7.45	4.45	10.45				6.15	2	3	3	8/30	8													
11					シルト質砂	淡褐				6.45	3	3	3	9/30	9										
12							7.15	3	3	3	9/30	9													
13							7.45	3	4	4	11/30	11													
14							8.15	4	4	5	13/30	13													
15							8.45	5	5	5	15/30	15													
16	1.30	6.15	16.60		砂礫	淡褐灰				9.15	7	7	9	23/30	23										
17							9.45	5	6	7	18/30	18													
18							10.15	7	8	9	24/30	24													
19							10.45	8	9	11	28/30	28													
20	-2.60	3.90	20.50				11.15	18	20	12/1	50/24	63													
21					岩塊混じり砂礫	淡褐～灰～淡褐				11.45	8	8	9	25/30	25										
22							12.15	12	15	18	45/30	45													
23							12.45	22	28		50/20	75													
24							13.15	50			50/5	300													
25							13.45	22	28		50/20	75													
26	-8.23	5.63	26.13							14.15	50			50/5	300										
27										14.45	50			50/5	300										
										15.15	50			50/5	300										
										15.45	50			50/5	300										
										16.15	50			50/5	300										
										16.45	50			50/5	300										
										17.15	50			50/5	300										
										17.20	50			50/5	300										
										18.15	18	20	12/1	50/24	63										
										18.39	18	20	12/1	50/24	63										
										19.15	18	20	12/1	50/24	63										
										20.15	8	8	9	25/30	25										
										20.45	50			50/5	300										
										21.00	50			50/5	300										
										21.10	50			50/5	300										
										22.15	12	15	18	45/30	45										
										22.45	50			50/5	300										
										23.15	50			50/5	300										
										23.20	50			50/5	300										
										24.15	22	28		50/20	75										
										24.35	50			50/10	150										
										25.15	50			50/10	150										
										25.25	50			50/10	150										
										26.15	50			50/8	188										
										26.23	50			50/8	188										